



Joseph F. McKernan Jr. Architects and Associates, LLC

Joseph F. McKernan Jr.,RA • John J. McQuilkin,AIA • Richard J. Lake,RA
Francis A. Witt

Rowan University – Rutgers Camden
Joint Health Sciences Center – Café Fitout

Addendum No. 2

June 1, 2020

Architect's Project No. 917A

SPECIFICATIONS:

- Form of Proposal: The April 7, 2020 Bid Date has been extended until July 1, 2020, see attached revised Form of Proposal.
- See attached new Alternate Section 012300 for the Add Alternate #1, listing the specified porcelain tile floor and base in Section 093013 to be bid as an Add Alternate.
- See attached revised Section 093013 listing the tile work as an add alternate.
- Section 013200 Construction Progress Documentation: In paragraph 1.5, A - delete requirement for a 'Scheduling Consultant', as the contractor may produce the schedule in house.
- Section 017839 Project Record Documents: In paragraph 1.2, B, 2 - delete the reference to a "Final Property Survey" as this will not be required for this project.
- Section 230900 Instrumentation and Control for HVAC: In paragraph 2.2, A, 1. Operating System - Change Microsoft Windows 8-1 to Microsoft Windows 10, connected to the existing Radius BAS system. The work is also to include updating/upgrading the graphics at the existing system interface to include the Café.
- Section 260923 Lighting Control Devices: Connect the lighting controls for the Café to the existing lighting control system via the nearest controller, as stated on the drawings.
- Section 283111 Digital Addressable Fire Alarm System: All new fire alarm devices are to be connected to the existing fire alarm system.

END OF ADDENDUM NO. 2